



North Central Texas Council of Governments

SUMMARY

Public Works Standard Drawings Subcommittee

Monday, March 16, 2020

10:00 AM – 11:30 AM, Cross Timbers Room

NCTCOG Offices, CP III

600 Six Flags Drive, Arlington, Texas 76011

1. **Welcome and Introductions.**

The Subcommittee met with an option to call-in.

2. **Meeting Summary.** The subcommittee can provide feedback on the February 24th meeting summary.

The Subcommittee had no edits or changes to the summary.

3. **Half Associates Task Order 5.** The subcommittee will review Task Order 5.

The Subcommittee had no comments on Task Order 5

4. **Division 2000 Drawings Review.** The subcommittee will continue reviewing the Division 2000 Drawings.

2120:

- No comments on 2120.

2125A and B:

- These are no longer ADA compliant. The subcommittee suggested using 2 or 3 of Fort Worth's or TxDOT's curb ramp details. Another suggestion was to remove 2125A and make updates based on the TxDOT details in 2125B. NCTCOG staff will bring examples to the next meeting for group to review.

2130:

- Put a vertical dimension of "6' min." on the paved part of the median nose.
- On the "4' min F. to F." dimension on the bottom drawing, move arrows to the outside lines or change to back to back.
- On the "6' min." dimension on the bottom drawing, move to the inside lines.
- After the "4" thick class" comment on the bottom drawing, add "as specified by owner."

2140

- Rename to "Low Profile Monolithic Concrete Median Nose."
- Add note, "As specified by owner."

2150A

- Change name to "Residential Driveway Approach."
- Show doweling like 2155.

2150B

- Change name to "Residential Driveway Approach."

616 Six Flags Drive, Centerpoint Two
P.O. Box 5888, Arlington, Texas 76005-5888
(817) 640-3300 FAX: 817-608-2372
www.nctcog.org

2155

- Change name to “Commercial Driveway Approach.”
- Add cross section view like 2150A
- Move dimension of “4’-6’ min.” on the left to under the sidewalk to curb.

2160

- Change name to “Commercial Driveway Approach.”
- Ask the rest of the subcommittee if it should be changed to #4 bars on 18” centers.

2170

- Ask the rest of the subcommittee if the Joint Lug drawing should be removed.
- Change note 2. to a sidewalk slope to 2% max.
- Ask the rest of the subcommittee if the concrete class should be changed to C.

2180

- Decrease wall height to 4’.
- Change the slope to 2% max.
- Change the compacted subgrade to 95% density.

2190

- Move this to be at the end of the pavement section
- Change note 2A to if PI is 15 use lime and if PI is less than 15 use cement or per geotech engineer recommendations.
- NCTCOG staff is to find if the manual in note 3 is still current.

5. **Next Steps.** Subcommittee will outline next steps to be taken by NCTCOG staff and the group as a whole before the next meeting.

NCTCOG staff will find examples of ADA compliant curb ramps for 2125 and look into the Regional Bicycle and Pedestrian Facility Design Manual on 2190.

6. **Next Meeting.** The Standard Drawings Subcommittee next meeting is Monday, April 13, 2020 as a conference call through WebEx.

7. **Adjournment.**

If you plan to attend this public meeting and you have a disability that requires special arrangements at the meeting, please contact Olivia Kale by email at okale@nctcog.org, 72 hours in advance of the meeting. Reasonable accommodations will be made to assist your needs.

