



North Central Texas Council of Governments

SUMMARY

Public Works Standard Drawings Subcommittee

Monday, August 23, 2021

10:00 AM – 11:30 AM

Cross Timbers Conference Room

NCTCOG Offices, CenterPoint III

616 Six Flags Drive, Arlington, TX 76011

1. **Welcome and Introductions.**
2. **Meeting Summary.** The subcommittee can provide feedback on the July 12th meeting summary.

The Subcommittee had no comments on the July 12th meeting summary.

3. **Division 2000 and 6000 Review.** The Subcommittee will review the completed edits made by NCTCOG staff to Division 2000 and 6000.

2130

- Add section A-A from Coppell details to show 7' sloped nose, add 7' sloped nose to "left turn" plan view like Coppell 2140 – don't need to increase 4" thickness
- Add note, "Sloped nose can be omitted if approved by owner"

2140

- Remove

2150A

- On top section it should be no. 3 bars at 18" centers, this needs to be updated in the specs
- Remove "payment for driveway" and "payment as curb and gutter" above section A-A
- Remove concrete under existing driveway, eliminating the header-like condition
- On Section A-A, "8" CTB" should be "Match existing street subgrade or 8" flexible base"
- On Note 3, change 6% to 10%, remove "all other" row and * should read "Maximum slope as approved by owner"
- Remove note 5.

2150B

- On top section it should be No. 3 bars at 18" centers.
- On Note 2, change 6% to 10%, remove "all other" row, and * should read "Maximum slope as approved by owner"
- Add note, "Use of rural section as approved by owner"

2150C

616 Six Flags Drive, Centerpoint Two
P.O. Box 5888, Arlington, Texas 76005-5888
(817) 640-3300 FAX: 817-608-2372
www.nctcog.org

- Remove “payment for driveway” and “payment as curb and gutter” above Section A-A
- It should be No. 3 bars on 18” centers
- Remove “8” lime and cement CTB” and change to “Match existing street subgrade or 8” flexible base”
- On top section, write “5’ typical” under varies

2155A

- Change top dimension to “Width 24’ min.”
- Remove “type A” from expansion joint callout
- Remove “per driveway ordinance” from radius note to the right of the section
- Change commercial radius to 25’ min
- Add note “turn lane as required”
- Add typical cross section
- Remove table
- Replace notes with residential driveway notes
- Use 6 sack concrete instead of 5.5
- Chris can review first draft of edits

2155B

- Visually show the top section as flat
- Remove “type A” from expansion joint callout
- Remove bottom section
- Add notes from residential driveway

2160A

- Remove design standards
- Curb should end at sidewalk
- Remove 10’ call-out for alley width, 15’ callout for ROW, 25.6’ call out distance, and 11.20 at P.T
- Call alley “Paving”
- Use 18” call out for 1.5’
- Stop curb graphic at street side of sidewalk
- 6’ min thickness on pavement for alley
- Add “begin invert transition” where PT point used to be; eliminate reference to p. 35 and 36.
- Match notes from residential driveway

2160B

- Add note, “subgrade shall match the alley pavement subgrade”

2170

- In plan view, instead “mark” it should be “see note 1”
- Section B-B, top note should be “light broom finish”
- Add note 3a. “If less than 6’, tooled joint to match width of sidewalk”
- Remove “translucent” from PVC Expansion cap
- Change to “expansion joint – see detail 2050” rather than ½” non-extruded pre-formed expansion material

2180

- Dimension at top should be 3” not 2”
- “9” x12” continuous pocket of clean 3/8” to 1 ½” stone with filter fabric”
- “backfill with native material after removal” not sand
- Remove #3 bars at 12” centers note at bottom and add #4 bars at 12” centers both ways



North Central Texas Council of Governments

- Remove asterisk at bottom
4. **Next Steps.** Subcommittee will outline next steps to be taken by NCTCOG staff and the group as a whole before the next meeting.
 5. **Next Meeting.** The Standard Drawings Subcommittee next meeting will be September 20, 2021 in the Cross Timbers Conference Room.
 6. **Adjournment.**

If you plan to attend this public meeting and you have a disability that requires special arrangements at the meeting, please contact Olivia Kale by email at okale@nctcog.org, 72 hours in advance of the meeting. Reasonable accommodations will be made to assist your needs.

616 Six Flags Drive, Centerpoint Two
P.O. Box 5888, Arlington, Texas 76005-5888
(817) 640-3300 FAX: 817-608-2372
www.nctcog.org

Attendance

Keith Marvin
Chris Cha
Edith Marvin
Brian Salvesen
Olivia Kale