



North Central Texas Council of Governments

# SUMMARY

## Public Works Standard Drawings Subcommittee

Monday, October 24, 2022

9:30 AM, In-Person Meeting

NCTCOG Offices, Regional Forum Room

616 Six Flags Drive, Arlington, Texas 76011

### 1. Welcome and Introductions.

Subcommittee member and staff introductions.

### 2. Division 2000 and 6000 Review. The Subcommittee will provide last comments before Divisions 2000 and 6000 are sent to the Public Works Council for approval.

#### 2020A

- Make curb ramp changes with stop bar look like what was done in drawings 2010-2015

#### 2020B

- Make curb ramp changes with stop bar look like what was done in drawings 2010-2015

#### 2030

- Make curb ramp changes with stop bar look like what was done in drawings 2010-2015

#### 2035

- Make curb ramp changes with stop bar look like what was done in drawings 2010-2015

#### 2040

- "Joints" misspelled in note 4

#### 2150A

- Note 3 needs cleaned up

#### 2150B

- Note 2 needs cleaned up

#### 2155A

- Note 3 needs cleaned up

#### 2155B

- Note 3 needs cleaned up

#### 2160

- Note 3 needs cleaned up

Division 6000 is ready for Public Works Council Approval

616 Six Flags Drive, Centerpoint Two  
P.O. Box 5888, Arlington, Texas 76005-5888  
(817) 640-3300 FAX: 817-608-2372  
[www.nctcog.org](http://www.nctcog.org)

3. **Division 4000 and 5000 Review.** The Subcommittee will provide comments on Divisions 4000 and 5000.

Division 4000 still needs edits that were requested during the January 10, 2022 Standard Drawings Subcommittee meeting.

5030

- Add “Use approved grade rings (18” max)”

5070

- Camera access edits to drawing

5090

- Remove hatching that goes through pipe (use hatch command 3 times)

5100

- Correct polyethylene misspelling in lower right side drawing

5120

- Add tracer wire above pipe
- Remove lower right arrow on lower drawing

5130

- Remove right arrow pointing at “Class B Concrete at Wye”
- Change pattern on left labeled “Class B Embed. if lateral slope exceeds 1:1, use Class A embedment” to match the Class “B” concrete at wye on right side

4. **Next Steps.** Subcommittee will outline next steps to be taken by NCTCOG staff and the group as a whole before the next meeting.

Subcommittee will meet for a work session on November 15<sup>th</sup> to work through Divisions 2000, 5000, 6000 and possibly 4000 to have them ready for Public Works Council review by January 2023 for a vote of approval at the February 2023 meeting.

5. **Next Meeting.** TBD – in December.

6. **Adjournment.**

If you plan to attend this public meeting and you have a disability that requires special arrangements at the meeting, please contact Liliana Sheppard by email at [lsheppard@nctcog.org](mailto:lsheppard@nctcog.org), 72 hours in advance of the meeting. Reasonable accommodations will be made to assist your needs.